

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 883

Dated: 26.8.2025

It is certified that an inspection team headed by SOMYA MISHRA (J.E. JALKAL)

(Name of Officers with designation) from Nagar Palika Parinabad, Stp PHED

inspected the SACRED HEART HIGHER SECONDARY SCHOOL, SITAPUR

(Name & Address of the school) on 29/07/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. U2208222 S30918665 dated 01/08/2025

of Dist. level water Analysis Lab (PHED Lab) certified that the

SACRED HEART HR. SEC. SCHOOL, SITAPUR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31st Mar, 2026.

Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :

To

SACRED HEART HIGHER SECONDARY
SCHOOL, 4 CANTT. ROAD SITAPUR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India
Address : Arya Nagar Water Tank , Sitapur



TC NO. 12225

Rept No	U2288222S30918665	Date	01-08-2025	Page No.	1
URL No.	TC122252500001500F				

Custmor Name SACRED HEART HIGHER SECONDARY SCHOOL

Basic details of sample

District	Sitapur	Block	--
Gram Panchayat	--	Village/Mohalla	--
Habitation	--	Location/Site Name	GAURA BARIK CHAWANI , 4 CANTT ROAD SITAPUR
Water Source	BOREWELL	Sample No.	45627
Quantity of Sample	1L	Date of Sample Collection	29-07-2025
Receiving Date	29-07-2025	Sample Collector	By Client
Sample Depositer	By Client	Sampling Method	17614 Part 01
Analysis Start Date	29-07-2025	Analysis Completion Date	31-07-2025

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25°C	-	7.06	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
2	Turbidity	(NTU)	0.31	1	5	IS 3025 (Part 10) : 2023
3	TDS	(mg/L)	650	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	80	250	1000	IS 3025 (Part 32): 2019
5	Total Alkalinity	(mg/L)	480	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	(mg/L)	448	200	600	IS 3025 (Part 21) : 2019
7	Calcium	(mg/L)	86.4	75	200	IS 3025 (Part 40) : 2023
8	Magnesium	(mg/L)	56.49	30	100	IS 3025 (Part 46) : 2023
9	Sulphate	(mg/L)	10.82	200	400	APHA 24 Edition -4500 S04 method (Turbidity method):2023
10	Nitrate	(mg/L)	10.54	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
11	Fluoride	(mg/L)	0.31	1	1.5	APHA 24 Edition -4500-F Method C (Electrode Method) : 2023
12	Iron	(mg/L)	BDL	1	No relaxation	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
13	Color	Hazen	<5	5	15	IS 3025 (Part 4): 2021

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Authorized Signatory

Prepared By

Chemist
Ankit Chauhan

Laboratory Contact details -: Email - stplabupjalnigam@gmail.com , Mob -: +91 8979986782

End of the report

LAB INCHARGE
District Level Water Analysis Laboratory
UPJN (RURAL), SITAPUR



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India

Rept No	U2288222S30918665	Date	01-08-2025	Page No.	2
---------	-------------------	------	------------	----------	---

Custmor Name	SACRED HEART HIGHER SECONDARY SCHOOL
--------------	--------------------------------------

Basic details of sample

District	Sitapur	Block	--
Gram Panchayat	--	Village/Mohalla	--
Habitation	--	Location/Site Name	GAURA BARIK CHAWANI , 4 CANTT ROAD SITAPUR
Water Source	BOREWELL	Sample No.	45627
Quantity of Sample	1L	Date of Sample Collection	29-07-2025
Receiving Date	29-07-2025	Sample Collector	By Client
Sample Depositer	By Client	Sampling Method	17614 Part 01
Analysis Start Date	29-07-2025	Analysis Completion Date	31-07-2025

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.coli	-	0.0	Shall Not Be Deducted in 100 ml sample		APHA 23rd Edition -9211B
2	T.coli	-	0.0	Shall Not Be Deducted in 100 ml sample		APHA 23rd Edition -9211B
3	FRC	(mg/L)	0.0	0.2	1.0	IS 3025 (Part 26):1986


Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By

Microbiologist

Authorized Signatory


Chemist
Ankit Chauhan

Laboratory Contact details :- Email - stplabupjalnigam@gmail.com , Mob :- +91 8979986782

End of the report